



# EXPLOSION PROTECTION CERTIFICATE OF CONFORMITY

Cert No. GYJ05240

This is to certify that the product

Electromagnetic Flowmeter Primary Head

manufactured by Krohne Altometer

(Address: Kerkeplaat 12, 3313LC Dordrecht, the Netherlands)

which model is Optiflux 5000/...-Ex

Ex marking Ex me ia II CT3~T6 / Ex de ia II CT3~T6

product standard /

drawing number 8.30700.01、8.30700.02

has been inspected and certified by NEPSI, and that it conforms  
to GB3836.1~4-2000、GB3836.9-1990

This Approval shall remain in force until 2010.08.14

Remarks 1、 Electromagnetic flowmeter primary head should used together with Optiflux 300F-Ex  
electromagnetic signal converter.

2、 The notes for safe use see the attachment I .

Director

National Supervision and Inspection Centre for  
Explosion Protection and Safety of Instrumentation

Issued Date 2005.08.15



This Certificate is valid for products compatible with the documents and samples approved by NEPSI.